

ADDENDUM NO. 2  
PROJECT MANUAL  
PHASE 1 IMPROVEMENTS  
SEWAGE TREATMENT PLANT NO. 2  
CONTRACT 1-2009  
CITY OF WASHINGTON, ILLINOIS

Bids will be received until 2 P.M., local time, August 5, 2009.

This Addendum to the Project Manual is issued to modify, explain, or correct the original Project Manual and is hereby made part of the Contract Documents. Insert the number of this Addendum in the blank space provided in the Bid, page 00400-2.

A. SPECIFICATIONS

1. DIVISION 16—ELECTRICAL

- a. Page 16480-2, SECTION 16480-MOTOR CONTROL, PART 2—PRODUCTS, Paragraph 2.01 A

CLARIFICATION: Variable frequency drives shall be as manufactured by Toshiba, or equal. This shall supersede the clarification made to Paragraph 2.05.E on Page 16480-7 in Addendum No. 1. Additionally, the manufacturer of the variable frequency drives does not need to be the same as the manufacturer of the MCCs as stated at the end of this paragraph.

\*\*\*\*\*  
**BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE  
SPACE PROVIDED IN THE BID FORM**  
\*\*\*\*\*

Dated at Madison, Wisconsin  
July 31, 2009

STRAND ASSOCIATES, INC.®  
910 West Wingra Drive  
Madison, WI 53715

