

DOCUMENT 00006

ADDENDA AND MODIFICATIONS

1. Date: April 18, 2011
2. Re: **ADDENDUM NO. 3**
3. Project: **NEW FIRE STATION FOR R.S.P. & E. FIRE PROTECTION DISTRICT**
571 State Highway 116
Roseville, IL 61473
4. To: ALL BIDDERS
5. From: Johnson Building Systems, Inc. (Construction Managers)
2188 McMasters Ave.
Galesburg, IL 61401
309-343-3148, FX: 309-343-0451
6. This Addendum forms part of and modifies Bidding and Contract Documents for the project named above. Acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject bidder to disqualification.
7. Where any original item called for in the Project Manual or indicated on the Drawings is supplemented by this addendum, the supplemental requirements shall supersede the previous item.
8. Where any original item is amended, voided, or superseded hereby, the other provisions of such items not specifically amended, voided, or superseded shall remain in effect.
9. This Addendum consists of this document and the following attachments:

PROJECT MANUAL

1. Section 15250-2, Paragraph 2.01.D.2. Revise to read "Domestic Cold and Hot Water Piping (Above Grade)". Add subparagraph 3. As follows:
 3. Heating Water Piping:
 - a. All sizes: 1-1/2" Fiberglass.

END OF DOCUMENT